



Kendall County Health Department

Environmental Health Unit

811 W. John Street, Yorkville, IL 60560

Phone: 630.553.9100 Ext. 8026 Fax: 630.553.9603

A Word About Permit Drawings.....

In order to ensure a timely and effective Health Department review of private sewage disposal system and/or well permit applications, please be certain to submit plans drawn to scale (one (1) inch equals 10', 20', or 30'), including specifications necessary to fully describe these utilities as follows:

For the private sewage disposal system in particular:

- The precise location (and assigned number) of each perc test hole or soil boring.
- Location of lot boundaries, street names, and easements on the property and within seventy-five (75) feet of the private sewage disposal system.
- Locations of all existing and proposed buildings, structures, driveways, roads, parking areas, sidewalks, patios, swimming pools, and other improvements.
- Location of all water lines within fifty (50) feet of the private sewage disposal system.
- The locations of all existing and proposed wells on the property and within seventy-five (75) feet of the property.
- A clearly described benchmark, maintained throughout the construction period, and used to determine the following: 1.) All elevations necessary to describe the sewage flow to and through the private sewage disposal system 2.) Existing and proposed finished grade topography 3.) Top of foundation (crown of the road may be used).
- The location of any body of water, drainage ditch, retention area, flood plain, wetlands, easements of any other surface water within one hundred (100) feet of system (check with the subdivision developer or Kendall County Planning, Building and Zoning for the accepted engineering plans). * The bottom of the seepage trench must be above the water elevation of any stream or body of water.

For the water well in particular:


- The well
- Lot boundaries, street names, and easements on the property
- Existing and proposed buildings, structures, driveways, roads, parking areas, sidewalks, patios, swimming pools, and other improvements.
- Existing and proposed private sewage disposal systems and/or public sewer service lines on the property and within seventy-five (75) feet of the property.
- Above ground (overhead) and below ground utilities.
- Barnyards and animal confinement lots; lake, ponds, streams or cisterns.

Note: The well should be located on ground which is higher than sources of contamination and shall have ready access for repairs, maintenance, treatment and inspection.

Please be informed that drawings lacking necessary information will be considered insufficient and promptly returned for completion.

Indicate North

SAMPLE DRAWING



LOT WIDTH 160 FT. LENGTH 242 FT. SCALE 1 IN. = 40 FT.

I HEREBY CERTIFY THAT, TO THE BEST OF MY KNOWLEDGE, THE PRECEDING INFORMATION IS CORRECT. THE WATER WELL AND SEWAGE DISPOSAL SYSTEM WILL BE INSTALLED AS OUTLINED IN THIS APPLICATION.

BILL SEPTIC CONTRACTOR

DATE 01 / 10 / 03

SIGNATURE PROPERTY OWNER OR CONTRACTOR

IMPORTANT: THE KENDALL COUNTY DEPARTMENT OF HEALTH & HUMAN SERVICES DOES NOT GUARANTEE TROUBLE-FREE OPERATION OF THIS SEPTIC SYSTEM BY THE ISSUANCE OF THE PERMIT OR BY THE FINAL APPROVAL OF THE INSTALLATION. THE PROPERTY OWNER ASSUMES FULL RESPONSIBILITY FOR ANY NUISANCE OR HEALTH HAZARD THAT MIGHT RESULT FROM ITS USE.

FINAL INSPECTION AND APPROVAL BY